



Certificate of Compliance

NRS Gate Valves

This certificate is issued for the following equipment:

Model 710U. Metal to Metal Seated Gate Valve. 2 ½ through 12 inch NPS. 175 psi (1205 kPa) rated working pressure. Available with the following end connections:

2 ½, 3, 4, 6, 8, 10, 12 Flanged

3, 4, 6, 8, 10, 12 Mechanical Joint

Approved for:

**Shield Fire, Safety and Security, Ltd.
11 Church Road
Great Bookham, Surrey
KT23 3PB, UK**

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 1120/1130

Project Identifier: 3021555

Date of Approval: October 12, 2004



An **FM** Global Enterprise

A handwritten signature in blue ink, appearing to read "Roger L. Altard", written over a horizontal line.

Roger L. Altard
Assistant Vice President

A handwritten signature in blue ink, appearing to read "Roger L. Altard", written over a horizontal line.

Date