



Certificate of Compliance

NRS Gate Valves

This certificate is issued for the following equipment:

Model 721U. Resilient Seated Gate Valve. 2 ½ through 12 inch NPS. 200 psi (1380 kPa) rated working pressure. Available with the following end connections:

2 ½, 3, 4, 6, 8, 10, 12	Flanged
2 ½, 3, 4, 6, 8, 10, 12	Mechanical Joint

Approved for: **Shield Fire, Safety and Security, Ltd.
11 Church Road
Great Bookham, Surrey
KT23 3PB, UK**

FM Approvals confirms that the items have been found to comply with the following standard:


FM Approvals Standard 1120/1130

Project Identifier: 3021555

Date of Approval: October 12, 2004



An FM Global Enterprise



Roger L. Allard
Assistant Vice President



Date