



Certificate of Compliance

OS&Y Gate Valves

This certificate is issued for the following equipment:

Model 762U. Metal to Metal Seated Gate Valve. 2 through 12 inch NPS. 175 psi (1205 kPa) rated working pressure. Available with the following end connections:

2, 2 ½, 3, 4, 6, 8, 10, 12 Flanged

Approved for: **Shield Fire, Safety and Security, Ltd.
11 Church Road
Great Bookham, Surrey
KT23 3PB, UK**

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 1120/1130

Project Identifier: 3021555

Date of Approval: October 12, 2004



An FM Global Enterprise


Roger L. Allard
Assistant Vice President


Date