



Certificate of Compliance

Swing Check Valves

This certificate is issued for the following equipment:

<i>Model Number</i>	<i>Description</i>	<i>Nominal Pipe Size</i>	<i>Max Working Pressure, psi (kPa)</i>	<i>Remarks</i>
763UM	Swing Check Valve, Flanged End Connections	3, 4, 6, 8, 10, 12 inch	200 (1380)	a
763UR	Swing Check Valve, Flanged End Connections	3, 4, 6, 8, 10, 12 inch	200 (1380)	b

Remarks:

- a. Bronze seat.
- b. Rubber seat.
- c. Dual Plate.
- d. No removable covers.

Approved for: **Shield Fire, Safety and Security, Ltd.**
11 Church Road
Great Bookham, Surrey
KT23 3PB, UK

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 1210

Project Identifier: 3021555

Date of Approval: October 12, 2004



All FM Global Enterprise


Roger L. Allard
Assistant Vice President


Date